

## Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 April 2026 to 30 April 2026

|               | Ardmore WTP<br>Treated A | Ardmore WTP<br>Treated B1 | Huia WTP<br>Treated | Papakura WTP<br>Treated | Pukekohe WTP<br>Treated | Waikato WTP<br>Treated | Waitakare WTP<br>Treated |
|---------------|--------------------------|---------------------------|---------------------|-------------------------|-------------------------|------------------------|--------------------------|
|               | mg/L                     | mg/L                      | mg/L                | mg/L                    | mg/L                    | mg/L                   | mg/L                     |
| 2 April 2026  | 0.02*                    | 0.03*                     |                     |                         | 0.1*                    |                        |                          |
| 6 April 2026  |                          |                           | 0*                  | 0*                      |                         |                        |                          |
| 7 April 2026  |                          |                           |                     |                         |                         |                        | 0.03*                    |
| 8 April 2026  | 0.03*                    | 0.03*                     |                     |                         |                         | 0.12*                  |                          |
| 10 April 2026 |                          |                           |                     |                         | 0.05*                   |                        |                          |
| 13 April 2026 |                          |                           | 0*                  | 0.02*                   |                         |                        |                          |
| 14 April 2026 |                          |                           |                     |                         | 0.78                    |                        | 0.75                     |
| 15 April 2026 | 0.79                     | 0.69                      |                     |                         |                         | 0.87                   |                          |
| 20 April 2026 |                          |                           | 0.86                | 0.73                    |                         |                        |                          |
| 21 April 2026 |                          |                           |                     |                         |                         |                        | 0.83                     |
| 22 April 2026 | 0.57*                    | 0.51*                     |                     |                         | 0.78                    | 0.04*                  |                          |
| 27 April 2026 |                          |                           | 0.87                | 0.85                    |                         |                        |                          |
| 28 April 2026 |                          |                           |                     |                         |                         | 0.65                   | 0.84                     |
| 30 April 2026 | 0.77                     | 0.74                      |                     |                         | 0.77                    |                        |                          |

## Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

### Note

Fluoride is added to Auckland's metropolitan water supply at the requirement of the Health (Fluoridation of Drinking Water) Act 2021.

The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

\* Fluoride instrument was out of service for maintenance; dosing was turned off while this occurred.