

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 June 2026 to 30 June 2026

	Ardmore WTP Treated A mg/L	Ardmore WTP Treated B1 mg/L	Huia WTP Treated mg/L	Papakura WTP Treated mg/L	Pukekohe WTP Treated mg/L	Waikato WTP Treated mg/L	Waitakare WTP Treated mg/L
1 June 2026			0.83	0.86			
2 June 2026							0.76
3 June 2026	0.07*	0.90				0.79	
5 June 2026					0.73		
8 June 2026			0.87	0.85			
9 June 2026					0.78		0.86
10 June 2026	0.89	0.91				0.85	
15 June 2026				0.86			
16 June 2026						0.86	
17 June 2026	0.09*	0.82			0.75		0.83
22 June 2026			0.83	0.85			
24 June 2026						0.89	0.82
25 June 2026	0.86	0.80			0.79		
29 June 2026			0.83	0.80			

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

Note

Fluoride is added to Auckland's metropolitan water supply at the requirement of the Health (Fluoridation of Drinking Water) Act 2021.

The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

* Fluoride instrument was out of service for maintenance; dosing was turned off while this occurred.