

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 March 2026 to 31 March 2026

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Papakura WTP Treated	Pukekohe WTP Treated	Waikato WTP Treated	Waitakare WTP Treated
	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
2 March 2026			0.80	0.83			
3 March 2026						0.78	0.77
5 March 2026	0.85	0.85			0.75		
9 March 2026			0.8	0.82			
10 March 2026							0.85
11 March 2026	0.83	0.78				0.85	
13 March 2026					0.75		
16 March 2026			*0.00	*0.00			
17 March 2026					*0.04		*0.00
18 March 2026	*0.04	*0.04				*0.12	
23 March 2026			0.86	0.85			
24 March 2026							0.84
25 March 2026	*0.05	*0.47			0.80	0.93	
30 March 2026			*0.00	*0.00			
31 March 2026						*0.11	*0.00

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

Note

Fluoride is added to Auckland's metropolitan water supply at the requirement of the Health (Fluoridation of Drinking Water) Act 2021.

The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

*Fluoride Dosing was off due to Fluoride Supplier Chain Testing.