Watercare
An Auckland Council Organisation

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

From 01 September 2026 to 30 September 2026

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Papakura WTP Treated	Pukekohe WTP Treated	Waikato WTP Treated	Waitakare WTP Treated
	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
1 September 2026	0.80	0.84	0.87	0.82	0.87	0.79	0.82
8 September 2026	0.80	0.81	0.85	0.82	0.89	0.79	0.80
15 September 2026	0.82	0.82	0.84	0.72	0.86	0.62*	0.80
22 September 2026	0.82	0.82	0.85	0.76	0.85	0.61*	0.87

Note

Fluoride is added to Auckland's metropolitan water supply at the requirement of the Health (Fluoridation of Drinking Water) Act 2021.

The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons.

*Fluoride dosing was low due to pipe maintenance work.