



Quarterly Summary

Māngere Wastewater Treatment Plant

Reporting period: September – November 2025

Issue Date: 9 December 2025

Watercare 

Executive Summary

Māngere Wastewater Treatment Plant (WWTP) achieved compliance with all effluent quality consent limits throughout the quarterly reporting period (September – October 2025). Process, influent, and biosolids monitoring was consistent with previous reporting periods.

No UV triggers for reactive shellfish monitoring were breached during this quarter. No complaints or comments in relation to plant operations were received by Watercare.

Midge control via chain dragging increased to weekly frequencies from September in accordance with the summer schedule. Weekly entomologist monitoring continued throughout and noted a moderate increase in midges over recent weeks, particularly around the intertidal storage basin, in response to calmer/warmer weather; however, overall numbers are still low in comparison to previous years.

Weekly onsite, and monthly community odour monitoring did not detect any significant odours.

37,039 tonnes of biosolids material was placed at the Puketutu Biosolids Facility during this quarter. The total storage capacity is estimated at four million tonnes, and the facility is currently at approximately 57% of capacity.

Table of Contents

1	COMPLIANCE REPORT	1
2	OPERATIONS REPORT.....	2
3	INFLUENT & BIOSOLIDS MONITORING	10
4	MIDGE CONTROL REPORT.....	16
5	ODOUR REPORT	18
6	CUSTOMER FEEDBACK REPORT	21
7	PUKETUTU ISLAND REPORT	22

1 COMPLIANCE REPORT

M-15 final effluent quality results


Table 1-1: Quarterly final effluent quality summary in relation to requirements of Consent 30083.

PARAMETER	SEPT-25	OCT-25	NOV-25		COMPLIANCE
					MONTHLY MEAN
BOD (g/m ³)	2.7	2.1	2.6	<	15
NFR (g/m ³)	7.3	4.8	4.8	<	15
Total Petroleum Hydrocarbon (g/m ³)	0.3	0.3	0.3	<	0.5
Ammoniacal Nitrogen (g/m ³)	0.8	0.3	0.9	<	5 ^(a)
Total Nitrogen (g/m ³)	8.1	7.4	7.8	<	35 ^(b)
Reactive Phosphorus (g/m ³)	1.4	1.8	1.9	<	9
Dissolved Oxygen, %saturation	94.9	96.9	99.1	>	80%
					MONTHLY MAXIMUM
BOD (g/m ³)	9.6	3.5	9.3	<	50
pH	7.6	7.5	7.6	<	9
Ammoniacal Nitrogen (g/m ³)	3.6	1.5	6.8	<	15 ^(a)
					MONTHLY MINIMUM
pH	7.1	7.1	7.1	>	6.5
					95%TILE OVER THREE DISCRETE MONTHS
BOD (g/m ³)	3.5			<	30
NFR (g/m ³)	10.0			<	30
					MONTHLY % UV MEASUREMENT
UV Dose Applied % Measurement	100.00	99.86	99.49	>	99.00

(a) Ammoniacal Nitrogen limits for the period of April-November inclusive. For December-March inclusive, the limits are 3 g/m³ for monthly mean and 6 g/m³ for monthly maximum.

(b) Total Nitrogen limit for the period of April-November inclusive. For December-March inclusive, the limit is 9.5 g/m³.

Rolling 12 months average daily plant inflow




2 OPERATIONS REPORT


Liquid Process

15-minute interval plant flow

There were seven RC Filter bypass events during this quarter. Please refer to the detailed information in the high flow diversion table. Secondary Treatment Capacity set point was 9.3 – 9.34 m³/s in this quarter.




Total Nitrogen removal and loading




Please note logarithmic scale on secondary vertical axis (Loading, T/d).

BOD removal and loading




Please note logarithmic scale on secondary vertical axis (Loading, T/d).

TSS removal and loading



Please note logarithmic scale on secondary vertical axis (Loading, T/d).

Number of Reactor Clarifiers in service



Reactor-Clarifier 1 was taken out of service for overhaul on 13 November.

UV based virus monitoring

Monitoring of enterovirus in shellfish samples is required in accordance with Special Condition 25(6) of Consent 30083 if one of the following conditions are triggered:

- Two consecutive exceedances of 80 cfu/100 mL for enterococci indicator bacteria (i.e., when no high flow diversion is occurring), measured twice daily in the UV effluent;
- Maximum UV dose is being applied to high flow diversion flows ($> 9 \text{ m}^3/\text{s}$) in accordance with required levels, but the applied UV dose is less than $35 \text{ mWs}/\text{cm}^2$ for more than 2 hours in non-high flow diversion channels; or
- In the event that effluent from the WWTP has not been subjected to the appropriate UV dose.

No reactive shellfish monitoring conditions were triggered during the reported quarter.





RC Filter High Flow Diversion event summary




Event Number	Start Date & Time	End Date & Time	Duration	Diverted Volume (m ³)	Secondary treated volume above 9m ³ /s (m ³)
#2023-09	29/12/2023 15:49	30/12/2023 17:35	23 hrs 32 mins	38,075	Data not available*
#2023-10	20/04/2024 13:09	20/04/2024 22:50	9 hrs 41 mins	67,178	Data not available*
#2023-11	20/05/2024 23:23	21/05/2024 22:50	23 hrs 27 mins	136,240	Data not available*
#2023-12	14/06/2024 4:33	15/06/2024 8:23	27 hrs 50 mins	162,264	Data not available*
#2023-13	16/06/2024 23:36	17/06/2024 19:01	19 hrs 25 mins	92,356	Data not available*
#2023-14	23/06/2024 6:18	24/06/2024 2:29	18 hrs 11 mins	98,975	Data not available*
#2024-01	20/07/2024 1:53	21/07/2024 14:35	1 d 12 hrs 42 mins	55,118	Data not available*
#2024-02	17/08/2024 19:17	18/08/2024 0:10	4hrs 54 mins	19,872	Data not available*
#2024-03	1/09/2024 4:24	1/09/2024 16:37	12hrs 17 mins	83,052	4,773
#2024-04	20/09/2024 14:39	21/09/2024 0:35	9 hrs 54 mins	58,334	47,431
#2024-05	3/10/2024 1:39	3/10/2024 15:30	13 hrs 54 mins	66,096	21,690
#2024-06	15/11/2024 14:35	15/11/2024 21:35	7 hrs	49,233	13,374
#2025-07	4/04/2025 9:06	5/04/2025 2:31	12 hrs 52 mins	87,460	32,087
#2025-08	19/04/2025 3:43	19/04/2025 17:24	12 hrs 9 mins	113,349	16,283
#2025-09	28/04/2025 3:42	28/04/2025 12:20	2 hrs 32 mins	13,055	1,398
#2025-10	30/04/2025 11:13	30/04/2025 12:08	35 mins	2,632	1,406
#2025-11	2/05/2025 15:05	2/05/2025 19:08	3 hrs 17 mins	15,217	4,527
#2025-12	9/05/2025 16:47	10/05/2025 16:53	18 hrs 5 mins	151,573	20,225
#2025-13	27/05/2025 8:24	27/05/2025 14:48	6 hrs 24 mins	36,498	21,989
#2025-14	29/05/2025 23:18	30/05/2025 2:03	2 hrs 48 mins	4,951	4,552
#2025-15	5/06/2025 22:23	6/06/2025 13:41	15 hrs 24 mins	91,585	61,405
#2025-16	9/06/2025 10:05	9/06/2025 15:05	5 hrs	15,133	13,320
#2025-17	10/06/2025 20:53	11/06/2025 21:59	1 day 1 hr 5 mins	205,387	58,992
#2025-18	12/06/2025 9:43	12/06/2025 19:01	9 hrs 18 mins	58,763	4,626
#2025-19	27/06/2025 11:06	28/06/2025 19:30	24 hrs 24 mins	189,565	13,984
#2025-01	3/07/2025 17:00	4/07/2025 13:54	21 hrs 6 mins	136,046	14,455
#2025-02	5/07/2025 0:00	5/07/2025 15:17	15 hrs 17 mins	10,903	5,133
#2025-03	11/07/2025 14:15	12/07/2025 21:03	1 d 7 hrs 12 mins	258,196	124,158
#2025-04	17/07/2025 10:28	17/07/2025 21:00	10 hrs 33 mins	79,571	41,842
#2025-05	29/07/2025 14:28	30/07/2025 16:00	1 d 2 hrs 24 mins	201,295	173,984
#2025-06	19/08/2025 10:12	19/08/2025 10:18	6 mins	411	312
#2025-07	12/09/2025 6:11	12/09/2025 21:19	13 hours 15 mins	95,427	14,058
#2025-08	24/09/2025 10:03	24/09/2025 23:47	11 hours 58 mins	76,053	12,924
#2025-09	14/10/2025 9:56	14/10/2025 23:38	12 hours 42 mins	99,177	15,545
#2025-10	24/10/2025 4:05	24/10/2025 4:18	13 mins	1,010	265
#2025-11	28/10/2025 11:13	28/10/2025 15:38	3 hours 3 mins	13,330	3,733
#2025-12	18/11/2025 22:51	19/11/2025 21:44	19 hours 56 mins	171,480	21,528
#2025-13	30/11/2025 18:16	1/12/2025 1:38	6 hours 10 mins	52,285	6,660

Note: High Flow Diversion event number convention follows the financial year, rather than calendar year.

*Volume treated through secondary treatment above the required 9m³/s started being reported from September 2024.


Influent chemistry monitoring






Solids Process

Primary and Secondary sludge ratio




Digester performance




Lower volatile solids results from the digester feed sludge on 19 and 26 November resulted in lower calculated volatile solids reduction.

Dewatering performance






One-off low centrifuge cake solids percentage on 8 September, potentially caused by the timing of sampling.




Imported Energy vs Biogas Generated Energy





3 INFLUENT & BIOSOLIDS MONITORING




Heavy Metals – Interceptors














Heavy Metals – Long-term trend in Biosolids









5 ODOUR REPORT

Weekly walkover odour offensiveness scores (inside Māngere WWTP)

Location	2 Sept 25	9 Sept 25	16 Sept 25	26 Sept 25	2 Oct 25	13 Oct 25	20 Oct 25	30 Oct 25	4 Nov 25	11 Nov 25	18 Nov 25	27 Nov 25	Avg. quarter
Digester Area	8	17	17	8	8	8	17	8	8	8	8	8	10
DAF's/DSFT	8	38	17	NA	17	17	17	4	8	8	8	17	13
GTB Biofilter	8	4	8	8	4	8	4	4	4	8	4	4	6
GBT Biofilter	8	0	4	8	0	8	4	17	4	0	8	0	5
CPB Biofilters	8	8	17	17	17	8	17	17	17	17	8	8	13
ASU Biofilters	4	17	17	8	17	4	17	17	8	17	4	17	12
BST Biofilters	8	17	17	8	4	17	8	4	4	8	NA	8	9
GT/GBT Building (old)	0	0	0	8	0	0	0	0	8	0	0	0	1
GT/GBT Building (new)	0	0	0	0	0	0	0	8	8	8	17	0	3
Centrif. ASU/Biosol. Bldg.	38	38	17	38	17	8	17	17	8	17	8	0	18
Blended Sludge Tank	8	17	8	8	8	17	8	17	8	8	17	17	12
EF3	17	4	8	8	4	8	4	8	8	8	0	4	7
EF4	4	17	4	4	8	4	17	4	4	8	4	4	7
EF5	4	4	4	4	4	4	4	8	0	4	4	4	4
Splitter Box Biofilter 1	8	8	8	4	8	4	8	8	8	4	8	8	7
Splitter Box Biofilter 2	8	8	8	4	8	8	8	4	8	8	17	17	9
Splitter Box Biofilter 3	8	8	17	17	17	8	8	17	17	17	17	17	14
Splitter Box Biofilter 4	4	4	4	17	8	4	4	8	8	8	4	8	7
IPS2	4	4	4	4	8	8	4	8	0	8	4	8	6
Primary (PSTs)	17	17	8	8	17	17	8	8	0	0	8	8	10
Screens Building	17	8	17	17	17	17	17	17	8	8	8	38	16
Tertiary (Filter & UV Plant)	4	4	4	4	4	8	4	4	4	4	4	4	5
RC1, RC2, RC4	8	8	17	8	8	8	8	8	8	8	8	8	9
RC3, RC5, RC6	8	8	8	8	8	8	8	8	8	8	8	8	8
RC7, RC8, RC9	8	8	8	8	8	8	8	8	8	8	8	8	8


Notes:

N/A = Location not accessible due to ongoing construction or maintenance.

Key - Odour offensiveness score		
Extremely Strong	80 - 100	
Strong	60 - 80	
Distinct	40 - 60	
Weak	20 - 40	
Very Weak	≤ 20	

Monthly walkover results (WWTP, Puketutu Island, and surrounding areas)

Mangere WTP & Puketutu Monthly Odour Scout Maximum Values Sept - Nov 2025



Notes:

- Three odour runs are completed per monitoring day (am, midday, pm). Maximum offensiveness score is the most distinct odour detected across the three runs.
- nd = No detectable odour at community location during any of the monthly monitoring rounds.
- Odour scout locations on x-axis listed clockwise from northern-most position as per Figure 5-1 below.

6 CUSTOMER FEEDBACK REPORT

No feedback in relation to the Māngere WWTP performance was received during this quarter.

7 PUKETUTU ISLAND REPORT

Placement of biosolids

37,039 tonnes of biosolids material was placed at the Puketutu Biosolids Facility during this quarter. Since the commencement of operations on 1 December 2014, Watercare has placed 2,272,000 tonnes of combined biosolids and cover/construction material. The total storage capacity is estimated at four million tonnes; therefore, the facility is currently at approximately 57% of capacity.




Figure 7-1: Material placement (biosolids and cover/construction) at Puketutu Biosolids Facility to date.

Biosolids truck movements were comparable to the previous quarter. Cover and construction material deliveries to the site have been high over the last two quarters to facilitate road and cell wall construction. Currently, Biosolids are deposited along the phase 5 embankment; this location doesn't allow the installation of long cells and forces the construction of multiple smaller cells. This has led to an increase in the number of cell walls to be built and subsequently more material required to be brought to the island.

Other matters

- No complaints were received at the Puketutu Biosolids Facility during the monitoring period.




Figure 7-2: Monthly truck deliveries to Puketutu Biosolids Facility




Figure 7-3: Monthly tonnages received at Puketutu Biosolids Facility